

C-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

**NEW DELHI- 110001**


No.F6/DFS/MS/School/2021/SZ/1002

Dated: 10/12/21

**FIRE SAFETY CERTIFICATE**

Certified that the J.B.M Public school running at ground plus two upper floors in a building comprised of ground plus three upper floors located at Nasir Pur New Delhi-110045 owned/occupied by J.B.M Public school was issued FSC vide letter no. F6/DFS/MS/School/2018/SZ/2627 dated 06/12/2018. The school building was re-inspected by the officer concerned of this department on dated 06/12/2021 in the presence of Dr. Amit Solanki (Manager). The building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi, and found that the building ( GF, FF & SF) is fit for occupancy class B 'Educational Building' with effect from 10/12/21 for a period of three years, subject to conditions printed overleaf.

Issued on 10/12/21 at New Delhi by

  
(Sunil Chawdhary)  
Dy. Chief Fire Officer

Copy to:-

1. The principal, J.B.M Public School, Nasir Pur, New Delhi-110045.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.